

Test Verification of Conformity

On the basis of the referenced test report(s), the sample(s) of the below product has been found to comply with the relevant harmonized standard(s) to the directive(s) listed on this verification at the time the tests were carried out. The manufacturer may indicate compliance to only the said directives by signing a DoC himself and may affix the CE marking to products identical to the tested sample(s) if the product complies with all CE marking directives that has the product in their scope. In addition, the manufacturer shall file and keep the documentation according to the rules of the applicable directive(s) and shall consider changes of the standards as they may occur. Additional requirements, additional directives and local laws may be applicable.

Applicant Name & Address : Shenzhen Veichi Electric Co., Ltd.
3rd Floor, Block C, Wentao Science and Technology Park,
Shiyan Yingrenshi Community, Baoan District, Shenzhen City,
China.

Product(s) Tested : PV Grid-interactive inverter

Ratings and principal characteristics : Rated AC output power: 500kW;
Maximum inverter efficiency: 98.9%;
Rated AC output voltage: 3×320V (delta connection) ;
Rated AC output frequency: 50Hz;
Rated AC output current: 902A;
MPPT voltage scope: 500 -850Vdc;
Maximum DC input voltage: 1000Vdc;
Maximum DC input current: 1260A;
IP20

Model(s) : SIT500KTL

Brand name : VEICHI

Relevant Standard(s) / Specification(s) / Directive(s) : EN 61000-6-2: 2005 Electromagnetic compatibility (EMC) - Part 6-2: Generic standards - Immunity for industrial environments
EN 61000-6-4: 2007+A1: 2011 Electromagnetic compatibility (EMC) - Part 6-4: Generic standards - Emission standard for industrial environments
EMC Directive 2004/108/EC

Verification Issuing Office Name & Address : Same as Legal Entity

Verification/Report Number(s) : 130129097GZU-A/ 130129097GZU-001

Note 1 : This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Helen Ma
Signature

Name: Helen Ma
Position: Sr. Project Engineer
Date: 07 June 2013